



# Certificate of Conformity

Product Certification Scheme 5

**Certificate No. 30739-01-21-INT**

This certificate applies to the product

**Passive infrared detector**

with name and/or type designation

**PG8944, 868MHz**

Placed on the market by

**Digital Security Controls**

3301 Langstaff Road, Concord, Ontario, Canada L4K 4L2

Produced in the manufacturing plant by

**Shanghai GES Information Technology Co. LTD**

668 Li Shi Zhen Rd, 201203 Shanghai Zhangjiang Hi-Tech Park, Shanghai, China

This certificate attests that all provisions concerning the assessment and the performance described in the standard

**EN 50131-2-2:2017**

are applied and that the product fulfil all the prescribed requirements

This Certificate is valid until 2025-06-09

Høvik, Norway 2021-06-09

For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen, Certification Manager



*Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.*

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. [www.applica.no](http://www.applica.no)

Certificate History		
Revision	Description	Issue Date
-	Initial Issue	2021-06-09

Product Covered by this Certificate		
Product Name	Product Description	Applied Standards
PG8944, 868MHz	PIR detector, wireless 868MHz	EN 50131-2-2:2017 EN 50131-1:2006+A2:2017+A3:2020 EN 50131-5-3:2017 EN 50131-6:2017 EN 50130-4:2011+A1:2014 EN 50130-5:2011

Products Specifications	
Product Name	Classification for EN 50131-6:2017
PG8944, 868MHz	Power supply type C

### Application/Limitation

- Security Grade 2
- Environmental Class IV
- Suitable for outdoor application

Documents Reviewed	
Document ID	Description
AF139250.01 VISIAS_Delta_EN.50131-2-2.38743_Rev1	Test reports for assessment of EN 50131-2-2:2017
E138990.00	Test report for assessment of EN 50130-4:2011/A1:2014
AE139251.01	Test report for assessment of EN 50130-5:2011
20350	Test report for assessment of EN 50130-5:2011, Clause 17
2122A7686	Test report for assessment of EN 50130-5:2011, Clause 19, 22, 23
AF149520.01 VISIAS_Delta_EN 50131-6.38743	Test reports for assessment of EN 50131-6:2017
VISRAD_EN.33307_EN 50131-5-3_433MHz	Test reports for assessment of EN 50131-5-3:2017
VISRAD_EN.33302_EN 50131-5-3_868MHz	
CN/SHA, APPLICA01	FPC Audit ID from July, 2019

**Notice:** The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

## Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the product listed above
- The product is to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The product listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the product
- Significant changes in the manufacturing plant
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE