



# Certificate of Continued Compliance 192350033/AA/01



Issued 12-04-2023 Replaces 192350033/AA/00  
Expiry date 12-03-2027 Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Wireless external siren  
Trademark: Vanderbilt  
Type designation: WSIR-EXT-B  
Hardware / Software: 03 / 1.0.0  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Vanderbilt International (IRL) Ltd.  
Address: Clonshaugh Business & Technology Park  
City: 17 DUBLIN  
Country: Republic of Ireland

This certificate is granted to:

Name of the certificate holder: Vanderbilt International (IRL) Ltd.  
Address: Clonshaugh Business & Technology Park  
City: D17KV84 DUBLIN  
Country: Republic of Ireland

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Security grade: 2

Environmental class: IV

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.  
Electromagnetic emission and safety aspects are not covered by this certificate.

Factory location:

CROW Electronic Engineering Ltd.

12 Kineret Street

Airport City

IL

Product inspection location:

SmartSD BV

Broekakkerweg 15

5126 BD Gilze

Netherlands

**Documentation lodged for this Certificate of Continued Compliance**

Test Reports:

- Hermon Laboratories Ltd.: CROENV\_EN.30126\_Rev1, 20 April 2020
- ANPI asbl: bis-rec-1431-00\_Class IV Wireless Outdoor Siren for SO2 test\_Crow Electronic Engineering Ltd, 26 April 2018
- Hermon Laboratories Ltd.: CROENV\_IEC.30126\_Rev1, 20 April 2020
- Hermon Laboratories Ltd.: CROIAS\_EN 50131-4.36619, 30 April 2020
- Hermon Laboratories Ltd.: CRORAD\_EN.36619\_EN 50131-5-3, 27 April 2020
- Hermon Laboratories Ltd.: CROEMC\_EN.36619, 27 April 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-4 April, 2019

**Applied Standards**

EN 50130-5 June, 2011  
EN 50130-4+A1 October, 2014  
EN 50131-5-3 March, 2017  
EN 50131-1+A1+A2+A3 June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Wireless external siren  
- Trademark: Vanderbilt  
- Type designation: WSIR-EXT-B  
- Hardware version: 03  
- Software version: 1.0.0

- Product description: Wireless external siren  
- Trademark: Vanderbilt  
- Type designation: WSIR-EXT-O  
- Hardware version: 03  
- Software version: 1.0.0

- Product description: Wireless external siren  
- Trademark: Vanderbilt  
- Type designation: WSIR-EXT-R  
- Hardware version: 03  
- Software version: 1.0.0