

Certificate of Conformity

Product Certification Scheme 5

Certificate No. 31344-03-23-INT

This certificate applies to the products

Wireless outdoor curtain PIR detector with antimasking

with names and/or type designations MP-902 PG2 (433 MHz), MP-902 PG2 (868 MHz), BW-902 (868 MHz)

Placed on the market by
Visonic Ltd.
13 Zarhin Street, Raanana, Israel

Produced in the manufacturing plant by

Shanghai GES Information Technology Co. LTD 668 Li Shi Zhen Rd, 201203 Shanghai Zhangjiang Hi-Tech Park, China

This certificate attests that all provisions concerning the assessment and the performance described in the standards

EN 50131-2-2:2017

are applied and that the products fulfils all the prescribed requirements

This Certificate is valid until 2027-07-17

Høvik, Norway 2023-07-17 For Applica Test & Certification AS

Jan Rum Kol



Jan Rune Pedersen, Certification Manager



Certificate No. 31344-03-23-INT

Certificate History			
Revision	Description	Issue Date	
_	Initial Issue	2023-07-17	

Products Covered by this Certificate			
Product Name	Product Description	Applied Standards	
MP-902 PG2 (433 MHz)	Wireless outdoor curtain PIR detector with	EN 50131-2-2:2017	
MP-902 PG2 (868 MHz)	antimasking.	EN 50131-1:2006+A1:2009+A2:2017	
BW-902 (868 MHz)		EN 50131-6:2017	
		EN 50131-5-3:2017	
		EN 50130-5:2011	
		EN 50130-4:2011+A1:2014	

Application/Limitation

- Security Grade 2
- Environmental Class IV
- Suitable for outdoor application

Documents Reviewed			
Document ID	Description		
VISIAS_EN 50131-2-2.31047	EN 50131-2-2:2017, EN 50131-1:2006+A1:2009+A2:2017		
VISIAS_EN 50131-6.31047_Rev1	EN 50131-6: 2017, EN50131-1:2006+A1:2009+A2:2017		
VISEMC_EN_31036_433_MHz	EN 50120 4:2011 : A1:2014		
VISEMC_EN_31036_868_MHz	EN 50130-4:2011+A1:2014		
VISRAD_EN.31047_EN 50131-5-3_433MHz	EN 50131-5-3: 2017		
VISRAD_EN.31047_EN 50131-5-3_868MHz			
VISENV_EN.31047	EN 50130-5:2011		
BIS/REC/1434			
CN/SHA Applica01	FPC Audit report		



Certificate No. 31344-03-23-INT

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plants
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE