



CERTIFICATE NUMBER

**0710002**

## EC Declaration of Conformity

In accordance with EN 45014:1998

WE DIGITAL SECURITY CONTROLS, A DIVISION OF  
TYCO SAFETY PRODUCTS CANADA LTD.  
OF 95 BRIDGELAND AVENUE, TORONTO, ONTARIO, CANADA M6A 1Y7  
DECLARE UNDER OUR SOLE RESPONSIBILITY THAT:

EQUIPMENT **ELECTRICAL AUTOMATIC CONTROL AND DELAY DEVICE**  
MODEL NUMBER **CFD4824 WITH CFD4800-EXT**

IN ACCORDANCE WITH THE FOLLOWING DIRECTIVES:  
89/106/EEC THE CONSTRUCTION PRODUCTS DIRECTIVE AS AMMENDED BY DIRECTIVE  
93/68/EEC

HAS BEEN DESIGNED AND MANUFACTURED TO THE FOLLOWING SPECIFICATIONS:  
EXTINGUISHMENT SYSTEMS EN 12094-1: 2003

ENVIRONMENTAL CLASS A  
PROTECTION LEVEL IP30  
FLOODING ZONE 1 TO 2  
CO<sub>2</sub>, INERT GAS, HALOGENATE HYDROCARBON  
EXPECTED OPTIONS : DELAY OF EXTINGUISHING SIGNAL  
MONITORING OF STATUS OF COMPONENTS  
EMERGENCY HOLD DEVICE  
CONTROL OF FLOODING TIME  
RESPONSE DELAY ACTIVATED CONDITION : 3S (MAX)  
RESPONSE DELAY TRIGGERING OF OUTPUTS : 1S (MAX)

NOTIFICATION BODY IMQ EC-CERTIFICATE OF CONFORMITY 0051-CPD-0118  
(0051)

I HEREBY DECLARE THAT THE EQUIPMENT NAMED ABOVE HAS BEEN DESIGNED TO COMPLY WITH THE  
RELEVANT SECTIONS OF THE ABOVE REFERENCED SPECIFICATIONS. THE UNIT COMPLIES WITH ALL  
ESSENTIAL REQUIREMENTS OF THE DIRECTIVES WHEN INSTALLED AND USED AS PER MANUFACTURER'S  
INSTRUCTIONS.



SIGNED BY:

NAME:

KEVIN HARRIS

POSITION:

MANAGER, APPROVALS SERVICES

DONE AT

VAUGHAN, ONTARIO, CANADA

UPDATED ON

10/19/2007