

Construction Products Regulations (305/2011/EU – CPR)

Declaration of Performance – 25990_00

1. Product: Xtralis VESDA VLF

2. Product Type:

allowing identification of the construction product as required pursuant to Article 11(4)

Models:

VLF-250-xx	250m ² coverage variant
VLF-500-xx	500m ² coverage variant

(where xx indicates the decal language)

French versions:

VLF-250-01NF	250m ² coverage variant
VLF-500-01NF	500m ² coverage variant

Options:

VIC-010	VESDAnet network card
VIC-020	Multifunction control card
VIC-030	Multifunction control card

Remote Units:

VRT-100	Remote Programmer
VRT-300	VESDAnet socket
VRT-V00	Remote VLF display unit (with 7 relays)
VRT-W00	Remote VLF display unit (no relays)
VRT-500	Remote relay unit (with 7 relays)
VSR-xxxx	These remote units may be rack mounted

Ancillaries:

E700-FILASSY	In line filter
VSP-850	In line filter

3. Intended use:

Aspirating smoke detectors for use in fire detection and fire alarm systems installed in and around buildings

4. Manufacturer:

Xtralis Pty Ltd
 4 North Drive, Virginia Park
 236-262 East Boundary Road
 Bentleigh East
 Victoria 3165
 Australia

5. European address:

*Xtralis UK Ltd
Peoplebuilding
Ground Floor
Maylands Avenue
Hemel Hempstead
Herts HP2 4NW*

6. System of assessment: System 1

7. The products are certified to the relevant harmonised standard(s) by:

*BRE Certification Limited and LPCB Notified Body Number: 0832
Bucknalls Lane
Garston
Watford
WD25 9XX*

who have performed product type tests, initial inspection and subsequent surveillance of factory production control under system 1 and have issued the following certificates:

- EC Certificate of Conformity Number: *0832-CPD-0771 (Australia)
0832-CPD-0987 (Malaysia)*

8. European Technical Assessment(s): Not relevant

9. Declared Performance: See next page

10. Declaration:

The performance of the product identified in points 1 and 2 are in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of the manufacturer

Name: Samir Samhouri

Position: CEO

Signature: 

Date: June 27, 2013

For aspirating smoke detectors the following table applies

Harmonised Technical Specification		EN 54-20:2006
Essential characteristics	Performance	Clause
Nominal activation conditions/sensitivity/response delay and performance under fire conditions:		
Response to slowly developing fires	<i>pass</i>	5.6
Repeatability	<i>pass</i>	6.2
Reproducibility	<i>pass</i>	6.3
Fire sensitivity (Class A, B &/or C)	<i>Class A,B & C⁽¹⁾</i>	6.15
Operational reliability:		
Individual alarm indication	<i>pass</i>	5.2
Connection of ancillary devices	<i>pass</i>	5.3
Manufacturer's adjustments	<i>pass</i>	5.4
On-site adjustment of behaviour	<i>pass</i>	5.5
Mechanical strength of the pipework	<i>pass</i>	5.7
Components in the sampling device	<i>pass</i>	5.8
Airflow monitoring	<i>pass</i>	5.9
Power supply	<i>pass⁽²⁾</i>	5.10
Data	<i>pass</i>	5.11
Software controlled detectors	<i>pass</i>	5.12
Tolerance to supply Voltage:		
Variation in supply parameters	<i>pass</i>	6.4
Durability of operational reliability:		
Temperature resistance:		
Dry heat (operational)	<i>pass</i>	6.5
Cold (operational)	<i>pass</i>	6.6
Vibration resistance		
Shock (operational)	<i>pass</i>	6.10
Impact (operational)	<i>pass</i>	6.11
Vibration sinusoidal (operational)	<i>pass</i>	6.12
Vibration sinusoidal (endurance)	<i>pass</i>	6.13
Electrical stability:		
Electromagnetic compatibility (EMC), immunity	<i>pass</i>	6.14
Humidity resistance:		
Damp heat, steady state (operational)	<i>pass</i>	6.7
Damp heat, steady state (endurance)	<i>pass</i>	6.8
Corrosion resistance:		
SO2 corrosion (endurance)	<i>pass</i>	6.9

(1) The class of any pipe/hole configuration and detector sensitivity is determined using ASPIRE2

(2) The detector should be supplied with power from a power supply conforming to EN 54-4