

# Certificate

of  
Continued Compliance

No: 162350002/AA/05

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **Alarm and life safety system**  
Trademark: **ZeroWire**  
Type designation: **ZW-6404**  
Hardware / Software version: **207175 / B0403002A58P002005-14**  
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**  
Address: **Kelvinstraat 7**  
City: **6003 DH WEERT**  
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**  
Address: **Kelvinstraat 7**  
City: **6003 DH WEERT**  
Country: **Netherlands**

Expiry date: **09 June 2020**

This certificate has THREE Annexes.

Zevenaar, 21 December 2018



Jan Willem Verwoert  
Project Manager



## Remarks and observations

The following conditions are applicable:

Security grade: 2  
Environmental class: II  
Equipment class: Fixed  
Power supply type: A

ATS classification:

LAN onboard interface: EN 50136-2:2013: SP4

GSM/ GPRS plug-in module ZW-7000 and variant ZW-7001: EN 50136-2:2013: SP3

GSM/ GPRS plug-in module ZW-7041, variant ZW-7041-ETI and ZW-7040: EN 50136-2:2013: SP3

Variant:

ZW-640-xxx where "xxx" denotes 2 or 3 character country suffix

According to EN 50131-1:2006+A1:2009, this equipment can be applied in installed systems up to and including security grade 2

Emission (EN 61000-6-3) and safety (EN 60950-1) has not been tested.

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication B.V.: 151200967-001-Ver 1.00, 02 June 2016
- Telefication B.V.: 151200967-003-Ver 1.00, 02 June 2016
- Telefication B.V.: 151200967-002-Ver 1.00, 02 June 2016
- Telefication B.V.: 151200967-005-Ver 1.00, 02 June 2016
- Telefication: 161200608- 001 Ver 1.00, 13 April 2017
- Telefication: 161001036-001-Ver 1.00, 20 April 2017
- Telefication: 180600055-005-Ver 3.00, 14 December 2018

### Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10	June, 2014
EN 50131-3	March, 2009
EN 50131-5-3	May, 2005
EN 50131-5-3/A1	October, 2008
EN 50131-6	January, 2008
EN 50131-6/A1	June, 2014
EN 50136-2	August, 2013

## Technical features and characteristics

The product includes the following features and characteristics:

### Alarm equipment using RF technics

- Operating frequency range: 433.65 MHz



**The product as described in this certificate includes the following type designations:**

- Product description: Alarm and life safety system  
- Trademark: ZeroWire  
- Type designation: ZW-6404  
- Hardware version: 207175  
- Software version: B0403002A58P002005-14

- Product description: Alarm and life safety system  
- Trademark: ZeroWire  
- Type designation: ZW-6404-xxx  
- Hardware version: 207175  
- Software version: B0403002A58P002005-14