

Certificate

of
Continued Compliance

No: 13229025/AA/02

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **Relay output expander**
Trademark: **Interlogix**
Type designation: **NX-507E**
Serial No: **N/A**
Hardware / Software version: **38-0019 revB / 755-A0032-5ABD**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

Expiry date: **19 February 2024**

This certificate has THREE Annexes.

Zevenaar, 20 February 2020



Jan Willem Verwoert
Project Manager





Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 190100674-ENV-Ver 2.00, 19 February 2020
- Telefication B.V.: 190100674-001-Ver 2.00, 20 February 2020
- Telefication: 20103348800 - Rev. 2, 09 February 2011
- ANPI asbl: bis-rec-698 add 11 UTC NX216 NX216EEN NX216Z8 NX507E NX508E NX534E, 28 October 2016

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
------------	-------------

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017



The product as described in this certificate includes the following type designations:

- Product description: Relay output expander
- Trademark: Interlogix
- Type designation: NX-507E
- Hardware version: 38-0019 revB
- Software version: 755-A0032-5ABD
- Serial number: N/A

- Product description: Output expander
- Trademark: Interlogix
- Type designation: NX-508E
- Hardware version: 38-0008 revB
- Software version: 755-A0032-5ABD
- Serial number: N/A