

Certificate of constancy of performance,

0832-CPR-F0900

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FC420CP-I Indoor Surface/Flush Mounting Analogue Addressable Type A Call Point with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Produced by or for

Control Equipment Ltd

Hillcrest Business Park
Cinderbank, Dudley
West Yorkshire
DY2 9AP
United Kingdom

and produced in the manufacturing plant(s)

KAC Alarm Company Ltd

KAC House, Thornhill Road
North Moons Moat
Redditch, Worcestershire
B98 9ND
United Kingdom


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-11:2001 + A1:2005 Manual call points EN 54-17:2005 Short circuit isolators

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 01 April 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.




M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 01 April 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0900

LEFT BLANK INTENTIONALLY



M McCullagh, Certification Manager
On behalf of BRE Global Limited
Date of issue: 01 April 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.