



Certificate of Continued Compliance 202350061/AA/00



Issued	25-02-2022	Replaces	
Expiry date	30-06-2023	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	CA Capture ceiling mount anti-mask dual technology PIR
Trademark:	Capture
Type designation:	AKHA0000
Serial No:	N/A
Hardware / Software:	AKHA0000 / FIR0179-0.1.x, Capture A20/CA Pyro Micro, FIR0180-1.4.x Capture CA Main Micro

Placed on the market under the name or trademark of:

Name of the manufacturer:	Texecom Ltd.
Address:	St Crispin Way
City:	BB4 4PW Haslingden (Lancashire)
Country:	GB

This certificate is granted to:

Name of the certificate holder:	Texecom Ltd.
Address:	St Crispin Way
City:	BB4 4PW Haslingden (Lancashire)
Country:	GB

Ron Scheepers
Managing director

This certificate has THREE Annexes.

CERTIFICATE

Telefication B.V.
Kiwa FSS Products
Wilmersdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

The x visible in the sw version stands for a digit that can change in case of minor changes.

The certified version is recorded in the certification file together with any reported minor changes.

Factory location:

Texecom Ltd

St Crispin Way

BB4 4PW, Haslingden

United Kingdom

Product inspection location:

JCL Logistics Benelux B.V.

Everdenberg 14

Oosterhout

The Netherland

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Element: TRA-045950-35-08A, 12 March 2020
- Telefication B.V.: 200300222-001-Ver. 1.00, 22 February 2022
- Telefication B.V.: 200300038-001-Ver. 1.00, 25 January 2021
- Telefication B.V.: 200300221-001-Ver. 2.00, 16 March 2021

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-4	January, 2008
--------------	---------------

Applied Standards

EN 50130-5	June, 2011
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2+A3	June, 2020

The product as described in this certificate includes the following type designations

- Product description: CA Capture ceiling mount anti-mask dual technology PIR
- Trademark: Capture
- Type designation: AKHA0000
- Hardware version: AKHA0000
- Software version: FIR0179-0.1.x, Capture A20/CA Pyro Micro, FIR0180-1.4.x Capture CA Main Micro
- Serial number: N/A