



Organismo Notificado N° 0370

# CERTIFICATE



No. **0370-CPR-3808**

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### FIRE DETECTION AND FIRE ALARM SYSTEMS:

- **PART 7: SMOKE DETECTORS. POINT DETECTORS USING SCATTERED LIGHT, TRANSMITTED LIGHT OR IONIZATION.**

REFERENCE: **JBE-2111** - ADDRESSABLE OPTICAL SMOKE DETECTOR

Place on the market under the name of:

## **JADE BIRD FIRE INTERNATIONAL (EUROPE), S.L.**

C/ DE TARRAGONA, 157 7º  
08014 BARCELONA (SPAIN)

And produced in the manufacturing plant:

**19/32301878**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 54-7:2018**

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 17<sup>th</sup> February 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

**The monitoring assessment will be done before February 2021**

Bellaterra, 17<sup>th</sup> February 2020

  
**Applus<sup>+</sup>**  
LGAI Technological Center, S.A.  
Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*This document is not valid without its technical annex; whose number coincides with the number of certificate.*

*The validity of this certificate can be checked on our website: <https://apps.applus.com/microsites/microsites/FECIP/login>*