LGAI Technological Center, S.A. (APPLUS) Campus UAB - Ronda de la Font del Carme s/n 08193 Bellaterra (Barcelona) T +34 93 567 20 00 www.applus.com



Cranismo Notificado Nº 0370-CPR-3811

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation *305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS:

PART 3: FIRE ALARM DEVICES. SOUNDERS

REFERENCE: JBE-2135 - ADDRESSABLE SOUNDER

Place on the market under the name of:

JADE BIRD FIRE INTERNATIONAL (EUROPE), S.L.

C/ DE TARRAGONA, 157 7° 08014 BARCELONA (SPAIN)

And produced in the manufacturing plant:

19/32301879

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 are applied and that the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 17th February 2020 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The monitoring assessment will be done before February 2021

Bellaterra, 17th February 2020

Applus[⊕]

LGAI Technological Center, S.A.

Xavier Ruiz Peña Managing Director, Product Conformity B.U.

This document is not valid without its technical annex; whose number coincides with the number of certificate.

The validity of this certificate can be checked on our website: <u>https://apps.applus.com/microsites/microsites/FECIP/login</u>

