



**0845 – CPR–232.1688**

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by Danish Institute of Fire and Security Technology, notified body No. 0845.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**STI IP67 WRP-R-01**

**Manual Call Point for outdoor use, IP67**

for applications related to automatic fire alarm systems

produced by

**STI (Europe)**  
**Unit 49G Pipers Road**  
**Park Farm Industrial Est., Redditch**  
**Worcestershire, B98 0HU**  
**England**

and produced in the manufacturing plant

**STI (Europe)**  
**Unit 49G Pipers Road**  
**Park Farm Industrial Est., Redditch**  
**Worcestershire, B98 0HU**  
**England**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN54-11:2001                      Fire detection and fire alarm systems –  
Part 11: Manual Call Points

EN54-11:2001/A1:2005        Fire detection and fire alarm systems –  
Part 11: Manual Call Points

under system 1 are applied and that the product fulfils all the prescribed requirements of the above mentioned standards.

This certificate was issued on **2013-07-11** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

The 2 attached annexes forms part of this certificate.

This certificate supersedes earlier version of this certificate, issued 2012-05-01.

Merete Poulsen

Tom Nisted

**DBI – Danish Institute of Fire and Security Technology**

Jernholmen 12, 2650 Hvidovre  
Tlf. Phone: 36 34 90 00, Fax: 36 34 90 01  
E-mail: dbi@dbi-net.dk  
www.dbi-net.dk



Prod. Reg. Nr. 7023