

## BRE Global

### Notified Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of constancy of performance

### 0832-CPR-F2416

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### 9-30783 Detector Module for Stratos ModuLaser (Branded AirSense)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

**UTC Fire & Security B.V.**  
Kelvinstraat 7  
NL-6003 DH  
Weert  
The Netherlands

and produced in the manufacturing plant(s):

**UTC CCS Manufacturing Polska SP. z.o.o**  
ul. Kolejowa 24  
39-100 Ropczyce  
Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-20:2006 Aspirating Smoke Detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 20 July 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 20 July 2018

Date of Issue: 17 December 2018

Issue number 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

**BRE Global Limited**

Bucknalls Lane,  
Garston, Watford,  
Hertfordshire, UK,  
WD25 9XX

**Notified Body No. 0832**

Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
web: [www.breglobal.com](http://www.breglobal.com)

**APPENDIX to Certificate of constancy of performance: 0832-CPR-F2416****9-30783 Detector Module for Stratos ModuLaser (Branded AirSense)**

Incorporating the following ancillary equipment:

-Apollo APIC Card for Stratos ModuLaser (Part No: 9-30430)

**Notes:**

1. For compliance with EN 54-20:2006, the Detector Module(s) (9-30783) must be used in conjunction with at least one of the following ancillary equipment:

- Command Display Module, (Part No: 9-30782)
- Standard Display Module, (Part No: 9-30781)
- Minimum Display Module, (Part No: 9-30780)

2. For compliance with clause 5.10 of EN 54-20:2006, all detectors and displays shall be supplied with power from a power supply conforming with the requirements of EN 54-4.

3. The device is approved for sensitivity Classes A, B and C. The Class of any pipework and hole configuration, detector sensitivity and equipment parameters must be determined using PipeCAD software.

4. The approval of the detector is conditional upon the following requirements:

- Design including accessories used, installation and commissioning are performed in accordance with the system installation manual 4-4001-501-1003.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 20 July 2018

Date of Issue: 17 December 2018

Issue number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).