



December 5, 2016

FirePro Systems LTD
Ghigo Gianfilippi de Parenti
6, Koumandarias Street & Spyrou Araouzou
Tonia Court No. 2, 1st Floor 3036
Limssol, Cyprus 54080

Our Reference: FILE EX6960, PROJECT 4787407118

Subject: STATUS UPDATE- LISTING INVESTIGATION FOR 15-YEAR LIFE OF
AEROSOL GENERATING FIRE EXTINGUISHING SYSTEM UNITS

Dear Ghigo:

This letter is to inform you that we have successfully completed UL Project 4787407118 to conduct agent aging tests for 15-yr life. A copy of the data generated under this project has been attached for your online records.

Also, all UL-Listed units previously manufactured under this file and volume also are certified for the 15-yr product life, as no changes affecting the product life have been made.

In no event shall UL be responsible to anyone for whatever use or non-use is made of the information contained in this Report and in no event shall UL, its employees or its agents incur any obligations or liabilities for damage, including, but not limited to, consequential damages arising out of or in connection with the use, or ability to use, the information contained in this Report. Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories LLC (UL) or any authorized licensee of UL.

Should you have any questions or comments regarding this project, please contact me.

Prepared by:

Eric Haberichter
UL Sr. Project Engineer
Fire Suppression
Eric.Haberichter@ul.com