



# Certificate of Continued Compliance 162350038/AA/03



Issued 19-01-2021  
Expiry date 30-06-2023

Replaces 162350038/AA/02  
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Wireless PIR/microwave detector 12m 433 MHz  
Trademark: Interlogix  
Type designation: RF-DD1012-K4  
Serial No: N/A  
Hardware / Software: 55-1007-F / 1.06  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: UTC Fire & Security B.V.  
Address: Kelvinstraat 7  
City: 6003DH Weert  
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: UTC Fire & Security B.V.  
Address: Kelvinstraat 7  
City: 6003DH Weert  
Country: Netherlands

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

# CERTIFICATE

Telefication B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

Power supply type: C

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

**Documentation lodged for this Certificate of Continued Compliance**

## Test Reports:

- Telefication B.V.: 150902083-013-Ver 1.00, 29 June 2016
- Telefication: 170900898-001-Ver. 1.00, 26 March 2018
- CNPP: AH200029 - RF-DD1012-K4\_20200710, 10 July 2020
- CNPP: LE 20 00 07 RevA\_20201221, 21 December 2020
- CNPP: LM 20 00 02-RF-DD1012-K4\_20200710, 08 January 2020

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-4

January, 2008

**Applied Standards**

EN 50130-5

June, 2011

EN 50131-5-3

March, 2017

EN 50130-4+A1

October, 2014

EN 50131-1+A1+A2

May, 2017

**The product as described in this certificate includes the following type designations**

- Product description: Wireless PIR/microwave detector 12m 433 MHz
- Trademark: Interlogix
- Type designation: RF-DD1012-K4
- Hardware version: 55-1007-F
- Software version: 1.06
- Serial number: N/A
  
- Product description: Wireless PIR/microwave detector 12m PI 433 MHz
- Trademark: Interlogix
- Type designation: RF-DD1012PI-K4
- Hardware version: 55-1007-F
- Software version: 1.06
- Serial number: N/A
  
- Product description: Wireless PIR/microwave detector 12m 868 MHz
- Trademark: Interlogix
- Type designation: TX-2413-03-1
- Hardware version: 55-1007-F
- Software version: 1.06
- Serial number: N/A
  
- Product description: Wireless PIR/microwave detector 12m PI 868 MHz
- Trademark: Interlogix
- Type designation: TX-2511-03-1
- Hardware version: 55-1007-F
- Software version: 1.06
- Serial number: N/A